

SUMTER MALL EXTERIOR
LIGHTING PLAN

REV.DATE: 8/27/08
VERIFIED BY: NANCY HOLMES

- NOTES:
- 1. WIRE TO EACH POLE IS #6 AWG. WIRE TO EACH LIGHT IS #10 AWG
 - 2. WIRE LOCATIONS ARE UNKNOWN
 - 3. ALL CONDUIT IS 1-1/2"
 - 4. ALL PULL BOXES ARE LOCATED AT THE BASE OF EACH POLE

LIGHTING INFORMATION					
Pole No.	Pole Height	Lamp Type	Wattage/Voltage	Last Repair Date	3yr Repair Total
1	65ft	Metal Halide	1000/240	02/04/10	
2	65ft	Metal Halide	1000/240	02/04/10	
3	65ft	Metal Halide	1000/240		
4	65ft	Metal Halide	1000/240	02/04/10	
5	65ft	Metal Halide	1000/240		
6	65ft	Metal Halide	1000/240		
7	65ft	Metal Halide	1000/240		
8	65ft	Metal Halide	1000/240		
9	65ft	Metal Halide	1000/240		
10	65ft	Metal Halide	1000/240		
11	65ft	Metal Halide	1000/240		
12	65ft	Metal Halide	1000/240		
13	65ft	Metal Halide	1000/240		
14	65ft	Metal Halide	1000/240		
15	65ft	Metal Halide	1000/240		
16	65ft	Metal Halide	1000/240		
17	65ft	Metal Halide	1000/240		
18	65ft	Metal Halide	1000/240		
19	65ft	Metal Halide	1000/240		
20	65ft	Metal Halide	1000/240		
21	65ft	Metal Halide	1000/240		
22	65ft	Metal Halide	1000/240		
23	65ft	Metal Halide	1000/240		
24	65ft	Metal Halide	1000/240		
25	65ft	Metal Halide	1000/240		
26	65ft	Metal Halide	1000/240		
27	65ft	Metal Halide	1000/240		
28	65ft	Metal Halide	1000/240	02/04/10	
29	65ft	Metal Halide	1000/240	02/04/10	

KEY

NL NIGHT LIGHT

↓ ↓

BULL HORN LIGHTS

⌒

WIRING

■

TRANSFORMERS

100A

PANELS

■

PULL BOXES

○

175W WALL PACKS

●

175W PEDESTRIAN LIGHT

●

100W COLUMN LIGHTS
- FLOOD LAMP

●

150W SWING LAMP

●

175W RECESS CAN



NUMBER OF LIGHTS OUT _____

DATE _____

MANAGER _____